

# Kitemark™ Certificate

This is to certify that:

Mobiak S.A.  
M. Mpotsari 96-98  
Chania Crete  
73136  
Greece

Holds Certificate Number:

KM 675727

In respect of:

**BS EN 3**  
**Portable fire extinguishers**

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

  
Chris Lewis - Certification Director, Product Certification

First Issued: 2017-06-02

Latest Issue: 2017-12-19

Effective Date: 2017-12-19

Expiry Date: 2020-12-18

Page: 1 of 2



003

...making excellence a habit.™

# Kitemark™ Certificate

No. KM 675727

Model No	Description
MBK17-010PA-VR	1 kg ABC powder, stored pressure. Fire rating 8A & 55B
MBK17-020PA-VR	2 kg ABC powder stored pressure. Fire rating 13A & 89B
MBK17-040PA-VR	4 kg ABC powder, stored pressure. Fire rating 21A & 113B
MBK17-060PA-VR	6 kg ABC powder, stored pressure. Fire rating 34A & 233B
MBK17-090PA-VR	9 kg ABC powder, stored pressure. Fire rating 43A & 233B
MBK17-120PA-VR	12 kg ABC powder, stored pressure. Fire rating 55A & 233B
MBK17-020AF-VR	2 litre foam, stored pressure. Fire rating 5A & 55B
MBK17-060AF-VR	6 litre foam stored pressure. Fire rating 21A & 144B
MBK17-090AF-VR	9 litre foam, stored pressure with aluminium valve. Fire rating 27A & 183B
MBK17-020FC-VR	2 litre Wet Chemical, stored pressure. Fire rating 5A, 34B & 40F
MBK17-060WT-VR	6 litre water, stored pressure. Fire rating 13A
MBK17-090WT-VR	9 litre water, stored pressure. Fire rating 21A
MBK17-020CA-VR	2 kg carbon dioxide. Fire rating 34B
MBK17-050CA-VR	5 kg carbon dioxide. Fire rating 89B
MBK17-050CA-AL-VR	5 kg carbon dioxide (250 bar). Fire rating 89B

All the above products are certified to BS EN 3-7:2004+A1:2007

First Issued: 2017-06-02  
Latest Issue: 2017-12-19

Effective Date: 2017-12-19  
Expiry Date: 2020-12-18

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.  
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.  
A member of BSI Group of Companies.